



California State Fire Marshal
CODE INTERPRETATION

Date Issued	06-17-02	Interpretation #	02-016
Topic	Occupancy Classification for Outpatient Dialysis Clinic		
Code Section(s)	1998 California Building Code Section 308.1		
Requested by	Joel Aranaz, Fire Marshal Fresno Fire Department 450 M Street Fresno, CA 93720		

What is the correct occupancy classification of an outpatient dialysis clinic with an occupant load of six or more?

The classification is a Group I, Division 1.2 occupancy.